CROSS CONNECTION PRACTICE EXAM (SAMPLE)

STUDY GUIDE



SAMPLE STUDY GUIDE WITH LIMITED QUESTIONS

VISIT US ONLINE FOR THE FULL VERSION STUDY GUIDE

https://crossconnection.examzify.com

Copyright © 2026 by Examzify - A Kaluba Technologies Inc. product.

ALL RIGHTS RESERVED.

No part of this book may be reproduced or transferred in any form or by any means, graphic, electronic, or mechanical, including photocopying, recording, web distribution, taping, or by any information storage retrieval system, without the written permission of the author.

Notice: Examzify makes every reasonable effort to obtain accurate, complete, and timely information about this product from reliable sources.

SAMPLE

Table of Contents

Copyright 1

Table of Contents 2

Introduction 3

How to Use This Guide 4

Questions 5

Answers 8

Explanations 10

Next Steps 16

SAMPLE

Introduction

Preparing for a certification exam can feel overwhelming, but with the right tools, it becomes an opportunity to build confidence, sharpen your skills, and move one step closer to your goals. At Examzify, we believe that effective exam preparation isn't just about memorization, it's about understanding the material, identifying knowledge gaps, and building the test-taking strategies that lead to success.

This guide was designed to help you do exactly that.

Whether you're preparing for a licensing exam, professional certification, or entry-level qualification, this book offers structured practice to reinforce key concepts. You'll find a wide range of multiple-choice questions, each followed by clear explanations to help you understand not just the right answer, but why it's correct.

The content in this guide is based on real-world exam objectives and aligned with the types of questions and topics commonly found on official tests. It's ideal for learners who want to:

- Practice answering questions under realistic conditions,
- Improve accuracy and speed,
- Review explanations to strengthen weak areas, and
- Approach the exam with greater confidence.

We recommend using this book not as a stand-alone study tool, but alongside other resources like flashcards, textbooks, or hands-on training. For best results, we recommend working through each question, reflecting on the explanation provided, and revisiting the topics that challenge you most.

Remember: successful test preparation isn't about getting every question right the first time, it's about learning from your mistakes and improving over time. Stay focused, trust the process, and know that every page you turn brings you closer to success.

Let's begin.

SAMPLE

How to Use This Guide

This guide is designed to help you study more effectively and approach your exam with confidence. Whether you're reviewing for the first time or doing a final refresh, here's how to get the most out of your Examzify study guide:

1. Start with a Diagnostic Review

Skim through the questions to get a sense of what you know and what you need to focus on. Your goal is to identify knowledge gaps early.

2. Study in Short, Focused Sessions

Break your study time into manageable blocks (e.g. 30 – 45 minutes). Review a handful of questions, reflect on the explanations.

3. Learn from the Explanations

After answering a question, always read the explanation, even if you got it right. It reinforces key points, corrects misunderstandings, and teaches subtle distinctions between similar answers.

4. Track Your Progress

Use bookmarks or notes (if reading digitally) to mark difficult questions. Revisit these regularly and track improvements over time.

5. Simulate the Real Exam

Once you're comfortable, try taking a full set of questions without pausing. Set a timer and simulate test-day conditions to build confidence and time management skills.

6. Repeat and Review

Don't just study once, repetition builds retention. Re-attempt questions after a few days and revisit explanations to reinforce learning. Pair this guide with other Examzify tools like flashcards, and digital practice tests to strengthen your preparation across formats.

There's no single right way to study, but consistent, thoughtful effort always wins. Use this guide flexibly, adapt the tips above to fit your pace and learning style. You've got this!

SAMPLE

Questions

SAMPLE

1. **Which type of assembly would best protect a fire suppression system from backflow?**

   A. Single Check Valve Assembly

   B. Double Check Valve Assembly

   C. Reduced Pressure Principle Assembly

   D. Reversed Pressure Breaker

2. **What term describes pressures less than that exerted by the atmosphere?**

   A. Vacuum

   B. Negative Pressure

   C. Low Pressure

   D. Barometric Pressure

3. **What is the best description of installing backflow prevention assemblies at the point of hazard within a premise?**

   A. External protection

   B. Point of Use protection

   C. Internal protection

   D. Site specific protection

4. **Which backflow preventer consists of two check valves and two shutoff valves?**

   A. Reduced Pressure Principle

   B. Atmospheric Vacuum Breaker

   C. Double Check Valve Assembly

   D. Pressure Vacuum Breaker

5. **What should individuals do with hoses to prevent cross connections?**

   A. Store them loosely in garages

   B. Keep them submerged in water sources

   C. Detach them and allow them to dry after use

   D. Wrap them tightly around pipes

SAMPLE

6. What is an example of a non-potable water source?

A. Tap water from a residential sink

B. Bottled drinking water

C. Irrigation water, industrial water, or reclaimed water

D. Water from a spring

7. What can lead to backpressure backflow?

A. Excessive use of drinking water

B. Elevated pressures in non-potable systems forcing water back into the potable supply

C. Removal of contamination sources

D. Regular maintenance of plumbing systems

8. Which device is commonly associated with reducing backflow in plumbing systems?

A. A pressure valve

B. A dual-check valve

C. A mixer tap

D. A hose connector

9. Who is typically responsible for testing backflow preventers?

A. A certified plumber

B. A certified electrician

C. A certified backflow tester

D. The property owner

10. To protect the potable water supply linked to a fire sprinkler system using a contaminated auxiliary water supply, what type of backflow preventer should be used?

A. Air Gap Device

B. Double Check Valve Assembly

C. Reduced Pressure Principle Backflow Assembly

D. Pressure Vacuum Breaker Assembly

SAMPLE

Answers

SAMPLE

1. C
2. A
3. C
4. C
5. C
6. C
7. B
8. B
9. C
10. C

SAMPLE

Explanations

SAMPLE

1. Which type of assembly would best protect a fire suppression system from backflow?

A. Single Check Valve Assembly

B. Double Check Valve Assembly

C. Reduced Pressure Principle Assembly

D. Reversed Pressure Breaker

The Reduced Pressure Principle Assembly is the most suitable choice for protecting a fire suppression system from backflow due to its design and operational characteristics. This type of assembly consists of two independently acting check valves with a pressure differential relief valve located between them. The primary function of the Reduced Pressure Principle Assembly is to prevent contaminants from entering the potable water supply. It achieves this by maintaining a pressure drop between the two check valves, which ensures that if a backflow condition occurs, water cannot flow backwards into the potable water supply. The relief valve serves as an additional safety feature; if the pressure between the check valves drops below a certain level, the relief valve opens to release any potentially contaminated water, ensuring that the supply remains safe. In the context of fire suppression systems, where the water used might be in contact with chemicals or other contaminants, maintaining water quality is crucial. The Reduced Pressure Principle Assembly is specifically designed for high-risk scenarios, making it ideal for use in fire suppression systems that are required to meet stringent health and safety regulations. Other assemblies, such as the Single Check Valve Assembly and the Double Check Valve Assembly, while they may provide a level of backflow prevention, they do not offer the same level of protection as a Reduced Pressure Principle Assembly, particularly

2. What term describes pressures less than that exerted by the atmosphere?

A. Vacuum

B. Negative Pressure

C. Low Pressure

D. Barometric Pressure

The term that describes pressures less than that exerted by the atmosphere is "vacuum." In a vacuum, the pressure is significantly lower than atmospheric pressure, which is the force exerted by the weight of air in the atmosphere. This concept is essential in various applications, including plumbing and cross-connection control, as a vacuum can lead to backflow, where contaminants may enter the clean water supply. While "negative pressure" might seem relevant, it typically refers to a pressure that is lower than the surrounding pressure, often used in contexts such as ventilation systems. However, "vacuum" is the more specific term that encapsulates the condition of reduced pressure relative to atmospheric levels. "Low pressure" can describe a general condition but does not imply the absence of air molecules like a vacuum does. "Barometric pressure," on the other hand, specifically refers to the atmospheric pressure measured by a barometer and is not related to conditions of vacuum. Thus, the appropriate term for pressures below atmospheric levels is indeed vacuum.

SAMPLE

3. What is the best description of installing backflow prevention assemblies at the point of hazard within a premise?

A. External protection

B. Point of Use protection

C. Internal protection

D. Site specific protection

The best description of installing backflow prevention assemblies at the point of hazard within a premise is internal protection. This approach entails placing devices within the building or facility where potential cross-connection hazards exist, ensuring that contaminants do not enter the potable water supply. By installing these assemblies at the point of hazard, you effectively protect the internal plumbing system and the public water supply from any backflow of unwanted materials. Internal protection is essential because it targets specific risks that may arise from various fixtures or appliances, such as hoses, sinks, or irrigation systems that could inadvertently introduce contaminants. By addressing these hazards where they occur, the integrity of the drinking water system is maintained, creating a safer environment for users. In addition to this, while external protection and point of use protection might suggest methods to mitigate risks from outside sources or specific usages, they do not capture the comprehensive focus on internal hazards that inner backflow prevention offers. Similarly, site-specific protection emphasizes the unique features or requirements of a particular location, which may not address the direct installation of backflow prevention devices at the hazardous points directly. Thus, internal protection best encapsulates the concept of safeguarding the water supply within a premise.

4. Which backflow preventer consists of two check valves and two shutoff valves?

A. Reduced Pressure Principle

B. Atmospheric Vacuum Breaker

C. Double Check Valve Assembly

D. Pressure Vacuum Breaker

The Double Check Valve Assembly is designed specifically to prevent backflow in plumbing systems and consists of two check valves positioned in series. The primary function of this assembly is to ensure that any water that has the potential to flow backward into the potable water supply is effectively stopped. Each check valve operates independently, providing an additional layer of protection against backflow. The configuration of this assembly is crucial because it effectively isolates the drinking water supply from potentially contaminated sources. Accompanying the two check valves are two shutoff valves, one located on either side of the check valves. These shutoff valves allow for maintenance and testing of the check valves without needing to drain the entire system, ensuring continued safety and compliance with plumbing codes. In contrast to other backflow preventers like the Reduced Pressure Principle or Pressure Vacuum Breaker, which have different configurations and operational mechanisms focused on specific situations, the Double Check Valve Assembly's specific setup of two check valves and two shutoff valves makes it uniquely effective for many general-purpose applications where contamination risk is present but not imminent.

SAMPLE

5. What should individuals do with hoses to prevent cross connections?

A. Store them loosely in garages

B. Keep them submerged in water sources

C. Detach them and allow them to dry after use

D. Wrap them tightly around pipes

Keeping hoses detached and allowing them to dry after use is important for preventing cross connections. When hoses are disconnected, it eliminates the potential for backflow, which can occur if the hose is left submerged or improperly stored. This backflow could allow contaminated water to enter the potable water supply, posing a health risk. Allowing hoses to dry also helps prevent the growth of bacteria and other pathogens that may thrive in wet environments. In contrast, options suggesting loose storage, submersion in water, or tight wrapping around pipes can create significant risks for cross connections. Storing hoses loosely may increase the chance of contamination while submerging them in water sources can lead to backflow issues. Wrapping hoses tightly around pipes might restrict flow or cause wear, but more importantly, it can create a scenario where water can seep back into the water supply. Hence, detaching and drying hoses is the best preventative measure against cross connections.

6. What is an example of a non-potable water source?

A. Tap water from a residential sink

B. Bottled drinking water

C. Irrigation water, industrial water, or reclaimed water

D. Water from a spring

A non-potable water source is one that is not safe for human consumption without treatment. Irrigation water, industrial water, and reclaimed water are all great examples of non-potable sources because they may contain contaminants or substances that could be harmful if ingested. Irrigation water, often used for agricultural purposes, can carry pesticides, fertilizers, and soil contaminants. Industrial water may have pollutants from manufacturing processes that render it unsafe for drinking. Reclaimed water, which is treated wastewater, is used in landscaping and irrigation but is not suitable for direct human consumption without further treatment. In contrast, tap water from a residential sink, bottled drinking water, and water from a spring are all typically treated and considered safe for consumption, making them examples of potable water sources. Understanding the differences between these categories is crucial in practices related to water safety and management.

7. What can lead to backpressure backflow?

A. Excessive use of drinking water

B. Elevated pressures in non-potable systems forcing water back into the potable supply

C. Removal of contamination sources

D. Regular maintenance of plumbing systems

Backpressure backflow occurs when there is an increase in pressure within a non-potable system, such as process water or irrigation systems, that exceeds the pressure in the potable water supply. This scenario creates conditions where contaminated water can flow back into the clean drinking water supply, posing significant health risks. In situations where non-potable systems experience elevated pressures—perhaps due to thermal expansion, pumping, or other factors—water can be forced into the potable supply if there are connections between the two systems. This emphasizes the need for proper cross-connection control measures to prevent possible contamination. The other options do not directly relate to backpressure backflow. For instance, excessive use of drinking water may stress the system, but it doesn't create a backpressure scenario. Similarly, the removal of contamination sources and regular maintenance of plumbing systems typically work to enhance water safety and system reliability, but they do not inherently create backpressure conditions.

SAMPLE

8. Which device is commonly associated with reducing backflow in plumbing systems?

A. A pressure valve

B. A dual-check valve

C. A mixer tap

D. A hose connector

The dual-check valve is an important device in plumbing systems that effectively helps prevent backflow. Backflow occurs when water flows in the opposite direction than intended, which can lead to contamination of the potable water supply. The dual-check valve contains two independent checks that close along with the flow direction, making it exceptionally reliable in preventing the reversal of flow. When water is flowing in the correct direction, both checks remain open, allowing for smooth water flow. However, if a backflow situation arises—such as a drop in pressure in the supply line—the checks close to prevent any possible contamination from entering the clean water supply. This makes the dual-check valve a key component of backflow prevention systems and enables compliance with plumbing codes designed to protect public health. Other devices mentioned do not specifically address backflow prevention in the same manner. Pressure valves are typically used to regulate water pressure, mixer taps blend hot and cold water but do not prevent backflow, and hose connectors can facilitate connections without addressing backflow risks. Thus, the dual-check valve stands out as the primary choice for reducing backflow issues in plumbing systems.

9. Who is typically responsible for testing backflow preventers?

A. A certified plumber

B. A certified electrician

C. A certified backflow tester

D. The property owner

The responsibility of testing backflow preventers is typically assigned to a certified backflow tester. This individual has undergone specialized training and certification to ensure they are knowledgeable about the various types of backflow prevention devices and the regulations surrounding their proper installation and maintenance. Backflow preventers are crucial for protecting potable water supplies from contamination due to backflow, which can occur when there is a change in water pressure. The certified backflow tester is skilled in performing the necessary tests to determine the functionality and effectiveness of these devices, ensuring compliance with local and state regulations. While a certified plumber may install backflow preventers, their training does not typically cover the specialized testing procedures required for these devices. Similarly, a certified electrician is not trained in plumbing systems or water safety, and although property owners have a vested interest in maintaining their systems, they generally lack the expertise and certification needed to properly test backflow preventers. Therefore, the certified backflow tester is the appropriate choice for this responsibility, reflecting their expertise in safeguarding water quality.

SAMPLE

10. To protect the potable water supply linked to a fire sprinkler system using a contaminated auxiliary water supply, what type of backflow preventer should be used?

A. Air Gap Device

B. Double Check Valve Assembly

C. Reduced Pressure Principle Backflow Assembly

D. Pressure Vacuum Breaker Assembly

The correct answer is the Reduced Pressure Principle Backflow Assembly, which is specifically designed to prevent backflow from contaminated sources into a potable water supply. This type of backflow preventer is particularly effective because it has two check valves and a pressure differential relief valve that maintains a reduced pressure zone. This design allows it to handle both backsiphonage and backpressure, making it suitable for protecting against potential contamination that may stem from a fire sprinkler system utilizing an auxiliary water supply. By maintaining a reduced pressure in the system, the Reduced Pressure Principle Backflow Assembly ensures that water cannot flow backward from the contaminated source into the clean water supply, effectively preventing cross connection hazards that could compromise public health. This is especially crucial when dealing with sources of contamination that may be more hazardous. In contrast, other devices, such as an air gap device or double check valve assembly, may not provide the same level of protection against all forms of backflow in scenarios where there is a high risk of contamination, particularly those associated with fire systems. A pressure vacuum breaker assembly is also less effective in scenarios involving constant pressure systems like those typically associated with fire sprinkler systems. Therefore, the Reduced Pressure Principle Backflow Assembly is the most suitable choice for this context.

SAMPLE

Next Steps

Congratulations on reaching the final section of this guide. You've taken a meaningful step toward passing your certification exam and advancing your career.

As you continue preparing, remember that consistent practice, review, and self-reflection are key to success. Make time to revisit difficult topics, simulate exam conditions, and track your progress along the way.

If you need help, have suggestions, or want to share feedback, we'd love to hear from you. Reach out to our team at hello@examzify.com.

Or visit your dedicated course page for more study tools and resources:

https://crossconnection.examzify.com

We wish you the very best on your exam journey. You've got this!

SAMPLE