FIRE SUPPRESSION EXAM 1 PRACTICE (SAMPLE)

STUDY GUIDE



SAMPLE STUDY GUIDE WITH LIMITED QUESTIONS

VISIT US ONLINE FOR THE FULL VERSION STUDY GUIDE

https://firesuppression1.examzify.com

Copyright © 2026 by Examzify - A Kaluba Technologies Inc. product.

ALL RIGHTS RESERVED.

No part of this book may be reproduced or transferred in any form or by any means, graphic, electronic, or mechanical, including photocopying, recording, web distribution, taping, or by any information storage retrieval system, without the written permission of the author.

Notice: Examzify makes every reasonable effort to obtain accurate, complete, and timely information about this product from reliable sources.

SAMPLE

Table of Contents

Copyright 1
Table of Contents 2
Introduction 3
How to Use This Guide 4
Questions 5
Answers 8
Explanations 10
Next Steps 15

SAMPLE

Introduction

Preparing for a certification exam can feel overwhelming, but with the right tools, it becomes an opportunity to build confidence, sharpen your skills, and move one step closer to your goals. At Examzify, we believe that effective exam preparation isn't just about memorization, it's about understanding the material, identifying knowledge gaps, and building the test-taking strategies that lead to success.

This guide was designed to help you do exactly that.

Whether you're preparing for a licensing exam, professional certification, or entry-level qualification, this book offers structured practice to reinforce key concepts. You'll find a wide range of multiple-choice questions, each followed by clear explanations to help you understand not just the right answer, but why it's correct.

The content in this guide is based on real-world exam objectives and aligned with the types of questions and topics commonly found on official tests. It's ideal for learners who want to:

- Practice answering questions under realistic conditions,
- Improve accuracy and speed,
- Review explanations to strengthen weak areas, and
- Approach the exam with greater confidence.

We recommend using this book not as a stand-alone study tool, but alongside other resources like flashcards, textbooks, or hands-on training. For best results, we recommend working through each question, reflecting on the explanation provided, and revisiting the topics that challenge you most.

Remember: successful test preparation isn't about getting every question right the first time, it's about learning from your mistakes and improving over time. Stay focused, trust the process, and know that every page you turn brings you closer to success.

Let's begin.

SAMPLE

How to Use This Guide

This guide is designed to help you study more effectively and approach your exam with confidence. Whether you're reviewing for the first time or doing a final refresh, here's how to get the most out of your Examzify study guide:

1. Start with a Diagnostic Review

Skim through the questions to get a sense of what you know and what you need to focus on. Your goal is to identify knowledge gaps early.

2. Study in Short, Focused Sessions

Break your study time into manageable blocks (e.g. 30 – 45 minutes). Review a handful of questions, reflect on the explanations.

3. Learn from the Explanations

After answering a question, always read the explanation, even if you got it right. It reinforces key points, corrects misunderstandings, and teaches subtle distinctions between similar answers.

4. Track Your Progress

Use bookmarks or notes (if reading digitally) to mark difficult questions. Revisit these regularly and track improvements over time.

5. Simulate the Real Exam

Once you're comfortable, try taking a full set of questions without pausing. Set a timer and simulate test-day conditions to build confidence and time management skills.

6. Repeat and Review

Don't just study once, repetition builds retention. Re-attempt questions after a few days and revisit explanations to reinforce learning. Pair this guide with other Examzify tools like flashcards, and digital practice tests to strengthen your preparation across formats.

There's no single right way to study, but consistent, thoughtful effort always wins. Use this guide flexibly, adapt the tips above to fit your pace and learning style. You've got this!

SAMPLE

Questions

SAMPLE

1. **According to NFPA 1901, how much soft intake hose must pumpers carry?**
   - A. 10 ft
   - B. 15 ft
   - C. 20 ft
   - D. 25 ft

2. **What does LPG stand for in the context of fuel gases?**
   - A. Liquid Petroleum Gas
   - B. Liquid Propane Gas
   - C. Lethal Propane Gas
   - D. Liquid Petroleum Grade

3. **What does FDC stand for in firefighting terminology?**
   - A. Fire Drain Connection
   - B. Fire Department Connection
   - C. Fire Disaster Control
   - D. Fire Defense Control

4. **Where should the power be turned off when dealing with electrical hazards?**
   - A. At the main breaker
   - B. At the wall switch
   - C. At the service panel
   - D. At the main panel

5. **What tool is utilized specifically to stop the flow of water in a hose line?**
   - A. Hose clamp
   - B. Ball valve
   - C. Siamese connection
   - D. Flow meter

6. **What is the minimum length of 1.5, 1.75, or 2 inch fire attack hose according to NFPA 1901?**
   - A. 200 ft
   - B. 300 ft
   - C. 400 ft
   - D. 500 ft

SAMPLE

7. Which of the following is NOT a primary component of salvage operations?

A. Forcible entry

B. Fire suppression

C. Water diversion

D. Ventilation

8. Why is it important to coordinate indirect attacks with ventilation during a fire suppression effort?

A. To maximize water use

B. To reduce smoke inhalation risk

C. To prevent flashover

D. To enhance visibility

9. What type of documentation must be maintained for evidence-related actions?

A. Spontaneous documentation

B. Accurate documentation

C. Visual documentation

D. Summarized documentation

10. What type of fuel includes roots and peat?

A. Surface fuel

B. Aerial fuel

C. Subsurface fuel

D. Ground fuel

SAMPLE

Answers

SAMPLE

1. B
2. A
3. B
4. D
5. A
6. C
7. D
8. C
9. B
10. C

SAMPLE

Explanations

SAMPLE

1. According to NFPA 1901, how much soft intake hose must pumpers carry?

A. 10 ft

B. 15 ft

C. 20 ft

D. 25 ft

The requirement for pumpers to carry a specific amount of soft intake hose is established by NFPA 1901, which sets the standards for the construction and equipment of fire department vehicles. According to NFPA 1901, pumpers are required to carry a minimum of 15 feet of soft intake hose. Soft intake hose is essential for connecting a pumper to a water source, such as a hydrant or drafting site, especially in situations where the water source may not be directly accessible. The designated length of 15 feet ensures that firefighters have a sufficient amount of hose to make these connections effectively, which is critical for maintaining water flow during fire suppression efforts. This standard helps ensure that fire response teams are adequately equipped to handle various water supply situations they may encounter in the field.

2. What does LPG stand for in the context of fuel gases?

A. Liquid Petroleum Gas

B. Liquid Propane Gas

C. Lethal Propane Gas

D. Liquid Petroleum Grade

LPG stands for Liquid Petroleum Gas, which is a term used to describe a group of flammable hydrocarbon gases that are commonly used as fuel for heating, cooking, and in vehicles. The designation "liquid" indicates that these gases can be stored under pressure in a liquid state, making them easy to transport and handle. Liquid Petroleum Gas primarily consists of propane and butane, which are derived from natural gas processing and petroleum refining. This fuel is popular due to its efficiency, clean-burning properties, and relatively low cost. Understanding the specific terminology in fuel gases is important for safety and operational procedures in fire suppression and related fields. Liquid Petroleum Gas is particularly relevant in scenarios involving fire hazards because it requires specific handling and storage protocols to reduce the risk of accidents or incidents.

3. What does FDC stand for in firefighting terminology?

A. Fire Drain Connection

B. Fire Department Connection

C. Fire Disaster Control

D. Fire Defense Control

In firefighting terminology, FDC stands for Fire Department Connection. This term refers to a critical component in fire suppression systems, specifically within standpipe or sprinkler systems. The Fire Department Connection allows firefighters to connect their hoses to the building's fire protection system to supplement the water supply during a fire. This connection is designed to enable quick access to the building's water supply and is strategically located to be easily accessible by emergency services. Properly identifying the FDC helps ensure that firefighters can efficiently combat fires, especially in larger structures where the existing water pressure may not be adequate. The design and placement of these connections are governed by fire codes and regulations to facilitate a rapid response by fire crews. Understanding the importance of the Fire Department Connection is essential for anyone involved in fire safety and suppression operations.

SAMPLE

4. Where should the power be turned off when dealing with electrical hazards?

A. At the main breaker

B. At the wall switch

C. At the service panel

D. At the main panel

Turning off the power at the main panel is the safest approach when dealing with electrical hazards. The main panel is typically the primary control point for all circuits in a building and allows for the deactivation of the entire electrical system when necessary. This minimizes the risk of electrical shock or fire by ensuring that no electricity flows to the circuits in question, thereby providing a secure environment for addressing any potential hazards. While the main breaker and service panel are both vital components of the electrical system, the terminology can sometimes vary based on regional practices or specific labeling within the panel. However, the main panel typically encompasses all breakers or switches and is the most comprehensive point for disconnecting power in case of emergencies. Turning power off at the wall switch is inadequate for safety when dealing with significant electrical hazards since it only disables a single circuit. It might not cut off the supply from the main source, which can still pose risks if other nearby circuits remain live.

5. What tool is utilized specifically to stop the flow of water in a hose line?

A. Hose clamp

B. Ball valve

C. Siamese connection

D. Flow meter

The hose clamp is designed to effectively stop the flow of water in a hose line. It works by physically constricting the hose, creating a seal that prevents water from continuing its passage through the hose. This capability is crucial in firefighting operations when it is necessary to temporarily halt the supply of water to inspect, repair, or change hose lines without shutting down the entire water supply. This tool ensures safety and efficiency during fire suppression activities by allowing firefighters to manage water flow as needed. In contrast, the other tools listed serve different functions. The ball valve is used to control flow by opening or closing a pathway but does not specifically clamp down on the hose. A Siamese connection is for merging multiple hose lines into one, facilitating water supply but not stopping flow. A flow meter measures the amount of water flowing through a line but does not control or stop the flow. Thus, the hose clamp is the most suitable tool for the specific purpose of halting water flow in a hose line.

6. What is the minimum length of 1.5, 1.75, or 2 inch fire attack hose according to NFPA 1901?

A. 200 ft

B. 300 ft

C. 400 ft

D. 500 ft

The minimum length of 1.5, 1.75, or 2 inch fire attack hose according to NFPA 1901 is 400 feet. This standard is designed to ensure that fire departments have an adequate supply of hose to effectively respond to various fire scenarios. A 400-foot length allows firefighters to effectively reach most structures and cover necessary distances on the fire scene. Having sufficient length is critical for optimizing attack strategies and ensuring efficient water delivery to manage fires effectively. Shorter lengths would potentially limit the operational range and effectiveness of fire suppression efforts, particularly in larger commercial or residential incidents where distances can be considerable. Therefore, the stipulation of 400 feet aligns with best practices in firefighting protocols to provide sufficient reach and flexibility in emergency situations.

SAMPLE

7. Which of the following is NOT a primary component of salvage operations?

A. Forcible entry

B. Fire suppression

C. Water diversion

D. Ventilation

Salvage operations are primarily focused on minimizing damage to property during and after a fire incident. The components of these operations include tactics aimed at protecting the client's belongings and reducing overall loss. Forcible entry, fire suppression, and water diversion are all actively involved in salvage operations. Forcible entry allows firefighters to gain access to areas where the fire might be spreading, which is crucial for protecting contents from further damage. Fire suppression is central to salvage operations as it directly addresses the fire's impact on the property. Water diversion helps manage the flow and accumulation of water, preventing additional water damage to the property. Ventilation, although important in firefighting to remove smoke and heat, is not specifically a salvage operation component. It is more related to fire control and preventing the fire from spreading rather than directly minimizing property damage once a fire is underway. Thus, ventilation is considered secondary to the primary objectives of salvage operations.

8. Why is it important to coordinate indirect attacks with ventilation during a fire suppression effort?

A. To maximize water use

B. To reduce smoke inhalation risk

C. To prevent flashover

D. To enhance visibility

Coordinating indirect attacks with ventilation is crucial to prevent flashover, a rapid and intense fire event that can occur when a fire ignites combustible materials in a room due to excessive heat buildup. During firefighting, if water is applied indirectly to cool the fire from a safe location, and ventilation is done strategically to manage the heat and smoke, it helps to lower the overall temperature in the area. Without proper ventilation, the heat and smoke can accumulate, increasing the risk of flashover. By ensuring that ventilation is aligned with the application of water, firefighters can reduce the chances of this dangerous phenomenon, providing a safer environment for both firefighters and any potential victims inside the structure. This coordinated approach creates an effective suppression strategy that minimizes the rapid escalation of the fire.

SAMPLE

9. What type of documentation must be maintained for evidence-related actions?

A. Spontaneous documentation

B. Accurate documentation

C. Visual documentation

D. Summarized documentation

Maintaining accurate documentation for evidence-related actions is crucial in the context of fire suppression and investigation. This type of documentation ensures that all details are recorded precisely, reflecting the actions taken and the evidence collected during an incident. Accurate documentation serves several essential purposes: it provides a reliable account of the procedures followed, supports the integrity of the evidence, and can be used in legal proceedings or investigations. This level of detail helps maintain accountability and transparency, which are fundamental in ensuring the credibility of the investigation and the actions taken by the responders. In contrast, the other options do not encompass the same level of detail or thoroughness necessary for evidence documentation. Spontaneous documentation may capture immediate observations but lacks the reliability of structured and accurate accounts. Visual documentation can be beneficial but does not include the comprehensive narrative and procedural details that accurate documentation provides. Summarized documentation, by its nature, condenses information and may omit critical details, thus failing to meet the rigorous requirements needed for legal or investigative purposes.

10. What type of fuel includes roots and peat?

A. Surface fuel

B. Aerial fuel

C. Subsurface fuel

D. Ground fuel

The correct answer pertains to subsurface fuel, which is characterized by its presence below the surface of the ground. This category includes organic materials such as roots and peat that can accumulate beneath the vegetation layer. These materials can play a significant role in fire behavior, particularly in how they can smolder and sustain combustion beneath the forest floor, even when surface conditions appear relatively moist or unburned. Subsurface fuel is crucial in understanding fire dynamics because it can ignite from a surface fire and may contribute to extended fire duration and the potential for deep-seated fires that can be difficult to detect and manage. Recognizing the characteristics and implications of subsurface fuel helps fire suppression teams make informed strategies regarding fire containment and control efforts, especially in environments where deep-rooted vegetation and organic layers are prevalent.

SAMPLE

Next Steps

Congratulations on reaching the final section of this guide. You've taken a meaningful step toward passing your certification exam and advancing your career.

As you continue preparing, remember that consistent practice, review, and self-reflection are key to success. Make time to revisit difficult topics, simulate exam conditions, and track your progress along the way.

If you need help, have suggestions, or want to share feedback, we'd love to hear from you. Reach out to our team at hello@examzify.com.

Or visit your dedicated course page for more study tools and resources:

https://firesuppression1.examzify.com

We wish you the very best on your exam journey. You've got this!

SAMPLE