
LEED AP WITH OPERATIONS AND MAINTENANCE (O+M) PRACTICE EXAM (SAMPLE)

STUDY GUIDE



SAMPLE STUDY GUIDE WITH LIMITED QUESTIONS

VISIT US ONLINE FOR THE FULL VERSION STUDY GUIDE

https://leedap-operationsandmaintenance.examzify.com

Copyright © 2026 by Examzify - A Kaluba Technologies Inc. product.

ALL RIGHTS RESERVED.

No part of this book may be reproduced or transferred in any form or by any means, graphic, electronic, or mechanical, including photocopying, recording, web distribution, taping, or by any information storage retrieval system, without the written permission of the author.

Notice: Examzify makes every reasonable effort to obtain accurate, complete, and timely information about this product from reliable sources.

SAMPLE

Table of Contents

Copyright 1

Table of Contents 2

Introduction 3

How to Use This Guide 4

Questions 5

Answers 8

Explanations 10

Next Steps 16

SAMPLE

Introduction

Preparing for a certification exam can feel overwhelming, but with the right tools, it becomes an opportunity to build confidence, sharpen your skills, and move one step closer to your goals. At Examzify, we believe that effective exam preparation isn't just about memorization, it's about understanding the material, identifying knowledge gaps, and building the test-taking strategies that lead to success.

This guide was designed to help you do exactly that.

Whether you're preparing for a licensing exam, professional certification, or entry-level qualification, this book offers structured practice to reinforce key concepts. You'll find a wide range of multiple-choice questions, each followed by clear explanations to help you understand not just the right answer, but why it's correct.

The content in this guide is based on real-world exam objectives and aligned with the types of questions and topics commonly found on official tests. It's ideal for learners who want to:

- Practice answering questions under realistic conditions,
- Improve accuracy and speed,
- Review explanations to strengthen weak areas, and
- Approach the exam with greater confidence.

We recommend using this book not as a stand-alone study tool, but alongside other resources like flashcards, textbooks, or hands-on training. For best results, we recommend working through each question, reflecting on the explanation provided, and revisiting the topics that challenge you most.

Remember: successful test preparation isn't about getting every question right the first time, it's about learning from your mistakes and improving over time. Stay focused, trust the process, and know that every page you turn brings you closer to success.

Let's begin.

SAMPLE

How to Use This Guide

This guide is designed to help you study more effectively and approach your exam with confidence. Whether you're reviewing for the first time or doing a final refresh, here's how to get the most out of your Examzify study guide:

1. Start with a Diagnostic Review

Skim through the questions to get a sense of what you know and what you need to focus on. Your goal is to identify knowledge gaps early.

2. Study in Short, Focused Sessions

Break your study time into manageable blocks (e.g. 30 – 45 minutes). Review a handful of questions, reflect on the explanations.

3. Learn from the Explanations

After answering a question, always read the explanation, even if you got it right. It reinforces key points, corrects misunderstandings, and teaches subtle distinctions between similar answers.

4. Track Your Progress

Use bookmarks or notes (if reading digitally) to mark difficult questions. Revisit these regularly and track improvements over time.

5. Simulate the Real Exam

Once you're comfortable, try taking a full set of questions without pausing. Set a timer and simulate test-day conditions to build confidence and time management skills.

6. Repeat and Review

Don't just study once, repetition builds retention. Re-attempt questions after a few days and revisit explanations to reinforce learning. Pair this guide with other Examzify tools like flashcards, and digital practice tests to strengthen your preparation across formats.

There's no single right way to study, but consistent, thoughtful effort always wins. Use this guide flexibly, adapt the tips above to fit your pace and learning style. You've got this!

SAMPLE

Questions

SAMPLE

1. **If a building is seeking credit for the efficiency of the DES under EA Credit, what should be included in the commissioning scope to earn Ongoing Commissioning?**

   A. Only upstream equipment

   B. All equipment including both upstream and downstream

   C. Only energy metering systems

   D. No specific requirements exist

2. **What is the maximum number of points that a data center project can earn under indoor water use reduction credit excluding the exemplary performance?**

   A. 2 points

   B. 3 points

   C. 4 points

   D. 5 points

3. **Which of the following elements does NOT need to be commissioned?**

   A. HVAC systems

   B. Lighting systems

   C. Passive solar design

   D. Water systems

4. **What type of buildings is Labs21 primarily concerned with when conducting energy assessments?**

   A. Educational facilities

   B. Healthcare buildings

   C. Laboratories

   D. Office complexes

5. **To earn Heat Island Reduction Roof, a project's roof must be covered by vegetation at least what percentage?**

   A. 30%

   B. 50%

   C. 70%

   D. 90%

SAMPLE

6. How frequently should new occupant surveys be performed to achieve EQ Credit Occupant Comfort Survey?

A. Every year

B. Once every two years

C. Every five years

D. Once every quarter

7. Which standards should a project team refer to for thermal comfort in a mechanically ventilated space?

A. ASHRAE 55-2010

B. ISO Standard 7730

C. CEN Standard EN 15251

D. ASHRAE 62.1

8. What should a site's storm-water management plan aim to achieve?

A. Complete removal of all water sources

B. Restore or enhance natural infiltration rates

C. Maximize impermeable surfaces

D. Minimize vegetation in the area

9. What criterion should be met for pesticide application communication according to the IPM?

A. All types of pesticides require occupants to be notified.

B. Only risk assessment outcomes should be communicated.

C. Notifications are mandatory for all pesticide applications.

D. Use of least-risk pesticides does not require notification.

10. CO2 sensors in mechanically ventilated areas must be calibrated to be accurate within how many ppm or percentage of the reading?

A. 50 ppm or 3%

B. 100 ppm or 4%

C. 75 ppm or 5%

D. 25 ppm or 2%

SAMPLE

Answers

SAMPLE

1. B
2. C
3. C
4. C
5. B
6. B
7. A
8. B
9. D
10. C

SAMPLE

Explanations

SAMPLE

1. If a building is seeking credit for the efficiency of the DES under EA Credit, what should be included in the commissioning scope to earn Ongoing Commissioning?

A. Only upstream equipment

B. All equipment including both upstream and downstream

C. Only energy metering systems

D. No specific requirements exist

Including all equipment, both upstream and downstream, in the commissioning scope is essential for earning Ongoing Commissioning for the efficiency of a District Energy System (DES) under the Energy and Atmosphere (EA) credit. This comprehensive approach ensures that the entire system is evaluated, optimized, and verified for performance. By encompassing all components of the DES, it allows for a detailed understanding of how each piece of equipment interacts and contributes to the overall energy efficiency. Upstream equipment refers to the major systems supplying energy, while downstream equipment includes those that distribute energy throughout the building. Commissioning both types of equipment helps identify issues, ensures the systems operate as intended, and facilitates continuous performance monitoring. The effectiveness of a DES relies on a holistic view of its components, as improvements in one area can significantly impact overall efficiency. Therefore, recognizing the interconnected nature of these systems and ensuring their optimal performance through ongoing commissioning is crucial for achieving energy efficiency credits in the LEED framework.

2. What is the maximum number of points that a data center project can earn under indoor water use reduction credit excluding the exemplary performance?

A. 2 points

B. 3 points

C. 4 points

D. 5 points

The correct answer reflects the prescribed structure of the indoor water use reduction credit within the LEED rating system, specifically for data centers. Under this credit, projects can earn points by demonstrating a reduction in water use compared to a calculated baseline. For standard projects seeking to achieve points under this credit, there are typically thresholds for water savings that correspond to specific point totals. In the case of data centers, which often exhibit unique water usage patterns due to their cooling systems and other operational needs, the credit framework allows for a maximum of four points. These points are awarded based on achieving significant reductions in water use, generally quantifying reductions through percentage decrease metrics. Exemplary performance opportunities can allow projects to earn additional points beyond the standard metrics. However, the question specifies the maximum points for regular credit attainment, not including exemplary performance, affirming that while contributions to sustainability can be acknowledged further, the baseline cap for the indoor water use reduction remains at four points.

SAMPLE

3. Which of the following elements does NOT need to be commissioned?

A. HVAC systems

B. Lighting systems

C. Passive solar design

D. Water systems

Passive solar design does not require commissioning in the same way that HVAC systems, lighting systems, and water systems do. Commissioning is a quality assurance process that ensures a building's systems are designed, installed, and functioning according to the owner's requirements and operational needs. It involves testing and documentation for complex mechanical and electrical systems to ensure they operate efficiently. HVAC systems, lighting systems, and water systems all involve active components that require ongoing performance monitoring and adjustment to meet energy efficiency and comfort standards. These systems benefit from thorough commissioning to verify that they are operating as intended, optimizing energy use and ensuring appropriate indoor environmental quality. In contrast, passive solar design relies on architectural elements such as building orientation, window placement, and thermal mass to naturally maintain comfortable indoor temperatures without the need for mechanical systems. This approach is inherently less complex and does not necessitate the same level of commissioning activities focused on monitoring and adjusting active systems. Thus, it is recognized as the option that does not require commissioning.

4. What type of buildings is Labs21 primarily concerned with when conducting energy assessments?

A. Educational facilities

B. Healthcare buildings

C. Laboratories

D. Office complexes

Labs21 is specifically focused on laboratories when conducting energy assessments. This initiative was developed to improve the energy efficiency and sustainability of laboratory buildings, which often consume significantly more energy than typical commercial buildings due to their specialized equipment and systems. Laboratories have unique operational demands, including the need for controlled environments, high levels of ventilation, and specific temperature requirements, which contribute to their energy-use intensity. By concentrating on laboratories, Labs21 aims to provide targeted solutions that help reduce energy consumption, improve operational efficiency, and minimize environmental impact. This focus enables a more nuanced understanding of the challenges and opportunities specifically present in laboratory environments, leading to more effective strategies for energy assessment and improvement.

SAMPLE

5. To earn Heat Island Reduction Roof, a project's roof must be covered by vegetation at least what percentage?

A. 30%

B. 50%

C. 70%

D. 90%

To earn the Heat Island Reduction Roof credit under the LEED O+M program, a roof must be covered by vegetation for at least 50% of its area. This requirement emphasizes the importance of green roofs in mitigating urban heat island effects, improving stormwater management, and providing additional benefits such as improved insulation and increased biodiversity. Vegetated roofs contribute to a reduction in heat absorption by the building, as they provide shading and evapotranspiration, which lowers the overall temperature of the roof surface compared to traditional roofing materials. This credit encourages project teams to incorporate green spaces that not only enhance the building's aesthetic appeal but also promote sustainability and environmental health. Therefore, the correct percentage of vegetative coverage required to qualify for this credit is 50%, highlighting the balance between a significant level of coverage to achieve demonstrable benefits while still being feasible for implementation on many structures.

6. How frequently should new occupant surveys be performed to achieve EQ Credit Occupant Comfort Survey?

A. Every year

B. Once every two years

C. Every five years

D. Once every quarter

To achieve EQ Credit Occupant Comfort Survey under the LEED O+M guidelines, it is recommended that occupant surveys be conducted at least once every two years. This frequency allows building management to gather relevant feedback from occupants regarding indoor environmental quality aspects such as lighting, acoustics, temperature, and overall satisfaction with the space. Conducting the survey biennially ensures that any issues or concerns related to occupant comfort can be identified and addressed in a timely manner, promoting a healthier and more productive environment. The data collected can be leveraged to make informed decisions regarding improvements and can help illustrate responsiveness to occupant needs, which is a key component in maintaining a high-performance building. In the context of other choices, conducting surveys every year may lead to redundant data collection without substantial changes or improvements being implemented between surveys. Conducting surveys every five years would not provide timely feedback and might allow issues affecting occupant comfort to persist for too long. Surveying once every quarter may also result in overwhelming data, creating unnecessary workload for management without providing significantly more value. Thus, once every two years strikes an appropriate balance between capturing valuable insights and managing survey frequency efficiently.

SAMPLE

7. Which standards should a project team refer to for thermal comfort in a mechanically ventilated space?

A. ASHRAE 55-2010

B. ISO Standard 7730

C. CEN Standard EN 15251

D. ASHRAE 62.1

ASHRAE 55-2010 is the correct reference for establishing acceptable thermal conditions in occupied spaces, particularly for those that are mechanically ventilated. This standard provides guidelines for thermal comfort based on a variety of factors, including temperature, humidity, air speed, and the clothing and metabolic levels of occupants. It aims to ensure that occupants are comfortable throughout different seasons and variations in temperature. ASHRAE 55-2010 outlines the criteria for evaluating thermal comfort, considering both environmental and personal variables. This makes it particularly suitable for a project team focused on indoor environmental quality and comfort within mechanically ventilated spaces. Other standards mentioned, such as ISO Standard 7730 and CEN Standard EN 15251, also address thermal comfort and might be applicable in specific contexts or regions. However, they do not provide the same comprehensive framework specifically tailored for utilizing mechanical ventilation systems. ASHRAE 62.1 primarily concerns ventilation requirements for acceptable indoor air quality rather than explicitly addressing thermal comfort.

8. What should a site's storm-water management plan aim to achieve?

A. Complete removal of all water sources

B. Restore or enhance natural infiltration rates

C. Maximize impermeable surfaces

D. Minimize vegetation in the area

The aim of a site's storm-water management plan should focus on restoring or enhancing natural infiltration rates. This approach is crucial because it helps to manage runoff, reduce erosion, and replenish local aquifers. Effective storm-water management recognizes the importance of allowing water to infiltrate into the ground rather than running off into drainage systems, which can overwhelm those systems and cause flooding. Enhancing natural infiltration contributes to the overall health of the ecosystem by maintaining groundwater levels and ensuring that local flora and fauna can thrive. This practice also supports sustainable landscape management by reducing reliance on water treatment facilities, improving water quality by allowing natural filtration processes to occur, and promoting the resilience of urban environments to manage storm-water effectively. Maximizing impermeable surfaces, removing all water sources, or minimizing vegetation would counteract these benefits, leading to increased runoff, decreased groundwater recharge, and potential harm to local ecosystems. These practices would not align with the objectives of sustainable infrastructure and storm-water management principles.

SAMPLE

9. What criterion should be met for pesticide application communication according to the IPM?

A. All types of pesticides require occupants to be notified.

B. Only risk assessment outcomes should be communicated.

C. Notifications are mandatory for all pesticide applications.

D. Use of least-risk pesticides does not require notification.

The correct choice emphasizes that when using the least-risk pesticides in an Integrated Pest Management (IPM) program, there is no requirement for formal notifications to occupants. This aligns with the principles of IPM, which prioritize minimizing risks to human health and the environment. The rationale behind this is that least-risk pesticides typically pose lower hazards compared to traditional chemical pesticides. In an IPM context, the use of these safer alternatives aims to strike a balance between effective pest control and the wellbeing of building occupants. Because these pesticides are deemed to carry less risk, it is understood that they are generally safer for individuals who might come into contact with treated areas, thus reducing the need for notifications. Looking at the other options, they suggest a broader scope that does not fit within IPM guidelines focused on risk assessment and communication. While some form of notification may be necessary for other types of pesticides—especially high-risk ones—the use of least-risk pesticides specifically allows for relaxed communication requirements as a recognition of their lower impact on health and safety.

10. CO2 sensors in mechanically ventilated areas must be calibrated to be accurate within how many ppm or percentage of the reading?

A. 50 ppm or 3%

B. 100 ppm or 4%

C. 75 ppm or 5%

D. 25 ppm or 2%

The correct choice emphasizes the importance of calibrating CO2 sensors in mechanically ventilated spaces to ensure accurate monitoring of indoor air quality. The calibration threshold of 75 ppm or 5% is specified to ensure that sensors can effectively detect and respond to varying levels of CO2 concentration, which is critical for maintaining a healthy indoor environment. In mechanically ventilated areas, appropriately calibrated sensors help in optimizing ventilation rates based on actual occupancy and air quality conditions. This contributes to effective energy management while ensuring that the indoor air quality meets health and comfort standards. Accurate sensor readings are essential for the timely adjustment of ventilation systems in response to CO2 levels, thus facilitating better occupant comfort and IAQ (Indoor Air Quality). The choice highlights how a range that balances precision (75 ppm) with a practical percentage (5%) supports both operational efficiency and comfort. This level of calibration allows for effective real-time monitoring, ensuring that the systems in place are functioning optimally. In contrast, other choices suggest calibration limits that either do not meet the necessary accuracy or offer lesser thresholds, which might not sufficiently cover the fluctuations that can occur in CO2 levels in various occupancy scenarios. The selected option strikes an optimal balance necessary for maintaining air quality and supporting ventilation system performance.

SAMPLE

Next Steps

Congratulations on reaching the final section of this guide. You've taken a meaningful step toward passing your certification exam and advancing your career.

As you continue preparing, remember that consistent practice, review, and self-reflection are key to success. Make time to revisit difficult topics, simulate exam conditions, and track your progress along the way.

If you need help, have suggestions, or want to share feedback, we'd love to hear from you. Reach out to our team at hello@examzify.com.

Or visit your dedicated course page for more study tools and resources:

https://leedap-operationsandmaintenance.examzify.com

We wish you the very best on your exam journey. You've got this!

SAMPLE