NFPA 16: STANDARD FOR THE INSTALLATION OF FOAM-WATER SPRINKLER AND SPRAY SYSTEMS PRACTICE TEST (SAMPLE)

STUDY GUIDE



SAMPLE STUDY GUIDE WITH LIMITED QUESTIONS

VISIT US ONLINE FOR THE FULL VERSION STUDY GUIDE

https://nfpa16.examzify.com

Copyright © 2026 by Examzify - A Kaluba Technologies Inc. product.

ALL RIGHTS RESERVED.

No part of this book may be reproduced or transferred in any form or by any means, graphic, electronic, or mechanical, including photocopying, recording, web distribution, taping, or by any information storage retrieval system, without the written permission of the author.

Notice: Examzify makes every reasonable effort to obtain accurate, complete, and timely information about this product from reliable sources.

SAMPLE

Table of Contents

Copyright 1

Table of Contents 2

Introduction 3

How to Use This Guide 4

Questions 5

Answers 8

Explanations 10

Next Steps 15

SAMPLE

Introduction

Preparing for a certification exam can feel overwhelming, but with the right tools, it becomes an opportunity to build confidence, sharpen your skills, and move one step closer to your goals. At Examzify, we believe that effective exam preparation isn't just about memorization, it's about understanding the material, identifying knowledge gaps, and building the test-taking strategies that lead to success.

This guide was designed to help you do exactly that.

Whether you're preparing for a licensing exam, professional certification, or entry-level qualification, this book offers structured practice to reinforce key concepts. You'll find a wide range of multiple-choice questions, each followed by clear explanations to help you understand not just the right answer, but why it's correct.

The content in this guide is based on real-world exam objectives and aligned with the types of questions and topics commonly found on official tests. It's ideal for learners who want to:

- Practice answering questions under realistic conditions,
- Improve accuracy and speed,
- Review explanations to strengthen weak areas, and
- Approach the exam with greater confidence.

We recommend using this book not as a stand-alone study tool, but alongside other resources like flashcards, textbooks, or hands-on training. For best results, we recommend working through each question, reflecting on the explanation provided, and revisiting the topics that challenge you most.

Remember: successful test preparation isn't about getting every question right the first time, it's about learning from your mistakes and improving over time. Stay focused, trust the process, and know that every page you turn brings you closer to success.

Let's begin.

SAMPLE

How to Use This Guide

This guide is designed to help you study more effectively and approach your exam with confidence. Whether you're reviewing for the first time or doing a final refresh, here's how to get the most out of your Examzify study guide:

1. Start with a Diagnostic Review

Skim through the questions to get a sense of what you know and what you need to focus on. Your goal is to identify knowledge gaps early.

2. Study in Short, Focused Sessions

Break your study time into manageable blocks (e.g. 30 – 45 minutes). Review a handful of questions, reflect on the explanations.

3. Learn from the Explanations

After answering a question, always read the explanation, even if you got it right. It reinforces key points, corrects misunderstandings, and teaches subtle distinctions between similar answers.

4. Track Your Progress

Use bookmarks or notes (if reading digitally) to mark difficult questions. Revisit these regularly and track improvements over time.

5. Simulate the Real Exam

Once you're comfortable, try taking a full set of questions without pausing. Set a timer and simulate test-day conditions to build confidence and time management skills.

6. Repeat and Review

Don't just study once, repetition builds retention. Re-attempt questions after a few days and revisit explanations to reinforce learning. Pair this guide with other Examzify tools like flashcards, and digital practice tests to strengthen your preparation across formats.

There's no single right way to study, but consistent, thoughtful effort always wins. Use this guide flexibly, adapt the tips above to fit your pace and learning style. You've got this!

SAMPLE

Questions

SAMPLE

1. Atmospheric-type foam concentrate outlets shall be located to accomplish what purpose?

A. Located at top

B. Located to prevent sediment from entering the system

C. Located near the vent

D. Located close to pump suction

2. Rate refers to the total flow of solution per unit time, expressed in which unit?

A. Bar

B. Liters Per Minute

C. Gallons Per Minute

D. Gallons Per Second

3. Testing residuals helps ensure that the system is free of what after maintenance?

A. Contaminants may remain if residual testing is not performed.

B. The foam concentration remains unchanged.

C. The system temperature is within limits.

D. No contaminants remain in the system after maintenance, ensuring safe operation.

4. In a balance-pressure system, which device maintains automatically the equal pressures between foam concentrate and water when using a pump discharging through a metering orifice into a controller?

A. A pressure balancing valve.

B. A relief valve.

C. A check valve.

D. A diaphragm.

5. Atmospheric-type tank discharge outlets shall be located to furnish what on the pump suction?

A. Provide a positive head on the pump suction

B. Provide a negative head on the pump suction

C. No head requirement

D. Varies by model

SAMPLE

6. Discharge devices and foam concentrates shall be listed for use together.

A. When Compatible With Water Supply

B. For Use Together

C. Only With Certain Devices

D. Not Required to Be Listed

7. For closed foam-water systems, how is foam concentration verified?

A. By visual observation

B. By flow tests at those two conditions

C. By colorimetric test

D. By manufacturer data sheet only

8. What is the primary function of foam piping within a foam-water sprinkler system?

A. To store water for the system

B. To drain the system during maintenance

C. To connect to the building's drainage system

D. To deliver foam concentrate from storage to the point of proportioning

9. Strainers shall be installed so as to be accessible for cleaning (flushing) while maintaining system discharge during an emergency. Which option best describes this requirement?

A. Strainers must be hidden for protection

B. Strainers must be positioned near the pump

C. Strainers shall be accessible for cleaning during emergencies

D. Strainers shall be installed so as to be accessible for cleaning (flushing) while maintaining system discharge during an emergency

10. Which foam concentrate is described as very similar to protein-foam concentrate but with a synthetic fluorinated surfactant additive?

A. Fluoroprotein foam concentrate

B. Aqueous film-forming foam concentrate

C. Protein foam concentrate

D. Medium and High-expansion foam concentrate

SAMPLE

Answers

SAMPLE

1. B
2. C
3. D
4. A
5. A
6. B
7. B
8. D
9. D
10. A

SAMPLE

Explanations

SAMPLE

1. Atmospheric-type foam concentrate outlets shall be located to accomplish what purpose?

A. Located at top

B. Located to prevent sediment from entering the system

C. Located near the vent

D. Located close to pump suction

Atmospheric-type foam concentrate outlets are positioned to keep sediment from entering the foam-water solution. Sediment can settle in the concentrate storage and, if drawn into the line, can clog the proportioner, valves, and piping, or degrade foam quality. By locating the outlet so it draws concentrate from a portion less likely to contain settled solids (typically away from the bottom), you minimize solids entering the system and help ensure reliable foam production. The other placements don't specifically prevent sediment ingress and thus don't address this core maintenance need.

2. Rate refers to the total flow of solution per unit time, expressed in which unit?

A. Bar

B. Liters Per Minute

C. Gallons Per Minute

D. Gallons Per Second

Flow rate is the amount of foam-water solution moving through the system per unit time, so it's described by a volume-per-time unit. In NFPA 16 and typical U.S. fire-protection practice, this flow rate is expressed as gallons per minute. Bar measures pressure, not how much fluid passes per time, so it doesn't fit as a rate. While liters per minute is a valid flow unit in metric contexts, the standard convention used here is gallons per minute, which aligns with pump and nozzle ratings, and with common design data. Gallons per second could describe flow too, but it's not the conventional unit used in these specifications.

3. Testing residuals helps ensure that the system is free of what after maintenance?

A. Contaminants may remain if residual testing is not performed.

B. The foam concentration remains unchanged.

C. The system temperature is within limits.

D. No contaminants remain in the system after maintenance, ensuring safe operation.

Residual testing after maintenance focuses on ensuring the system is free of contaminants that could affect foam quality and overall operation. When a foam-water system is serviced, cleaners, debris, corrosion byproducts, or other residues can linger in pipes, valves, or components. If these residues stay, they can foul the foam solution, clog passages, or react with the foam concentrate, compromising performance when the system is needed. The best answer expresses the aim of testing after maintenance: to verify that no contaminants remain in the system, ensuring safe and reliable operation. The other options don't directly address the cleanliness goal—foam concentration stability, temperature limits, or simply noting that contaminants could remain if testing isn't done don't capture the imperative to prove the system is completely free of contaminants before use.

SAMPLE

4. In a balance-pressure system, which device maintains automatically the equal pressures between foam concentrate and water when using a pump discharging through a metering orifice into a controller?

A. A pressure balancing valve.

B. A relief valve.

C. A check valve.

D. A diaphragm.

Balance-pressure systems rely on automatically equalizing the pressure on the foam concentrate line to the water line so the metering orifice sees a consistent driving pressure and the foam solution is proportioned correctly. The device that does this automatically is a pressure-balancing valve. It sits in the concentrate supply and senses the water line pressure; as water pressure changes, it adjusts concentrate flow to keep the two pressures essentially equal. This keeps the metering action stable across varying demands, preventing over- or under-proportioned foam. A relief valve would vent excess pressure and doesn't maintain equal pressures between the two streams; a check valve prevents backflow but doesn't balance pressures; a diaphragm is a component inside some valves but not the balancing device itself.

5. Atmospheric-type tank discharge outlets shall be located to furnish what on the pump suction?

A. Provide a positive head on the pump suction

B. Provide a negative head on the pump suction

C. No head requirement

D. Varies by model

The key idea is that the tank's discharge outlet for an atmospheric-type storage system must create positive hydrostatic pressure at the pump suction. When the water in the tank is at a depth relative to the suction inlet, the hydrostatic head pushes water into the pump, helping to keep the pump primed and preventing air from entering the suction. By locating the outlet deeper in the tank, you ensure a positive head is present at the suction, which improves reliability during foam-water discharge. If the outlet were high or near the surface, the head could be near zero or even negative, increasing the risk of loss of prime or cavitation. The standard specifies maintaining this positive head consistently, so it doesn't vary by model.

6. Discharge devices and foam concentrates shall be listed for use together.

A. When Compatible With Water Supply

B. For Use Together

C. Only With Certain Devices

D. Not Required to Be Listed

The key idea is compatibility verified by listing. In foam-water sprinkler systems, the discharge devices (like foam outlets, nozzles, and eductors) must be tested and approved to work with specific foam concentrates. When a combination is listed for use together, it means a recognized testing laboratory has evaluated and approved that exact pairing, so the foam concentrate will mix correctly with water and pass through the discharge devices as intended. This ensures reliable foam quality, proper surge and drainage, and overall system performance. Choosing the option that states they shall be listed for use with each other is the best answer because it explicitly requires that the components be evaluated together, not just generally compatible or used with water supply. Options suggesting compatibility with water alone, restricting to certain devices, or not requiring listing do not guarantee the necessary tested combination and could lead to improper performance or safety concerns.

SAMPLE

7. For closed foam-water systems, how is foam concentration verified?

A. By visual observation

B. By flow tests at those two conditions

C. By colorimetric test

D. By manufacturer data sheet only

In a closed foam-water system, you're testing that the foam concentrate is being blended with water at the correct proportion when the system is in use. The amount of foam concentrate delivered depends on flow rate and operating conditions, and those factors can shift as pumps start, valve positions change, or flow rates vary. Because of that, the most reliable way to confirm the delivered foam concentration is to perform flow tests at two specified flow conditions and measure the actual foam-concentration at the discharge. This direct, quantitative check shows whether the proportioning device maintains the intended ratio across the system's operating range. Visual observation isn't dependable for determining concentration, and colorimetric tests, while possible in some contexts, don't replace the need to verify performance under real operating conditions in a closed system. Relying solely on the manufacturer data sheet ignores field variables and operating realities, so it wouldn't ensure the system actually delivers the correct concentration during a fire scenario.

8. What is the primary function of foam piping within a foam-water sprinkler system?

A. To store water for the system

B. To drain the system during maintenance

C. To connect to the building's drainage system

D. To deliver foam concentrate from storage to the point of proportioning

The main idea is that foam piping is the delivery path for the foam concentrate. In a foam–water sprinkler system, water and foam concentrate are kept separate until they reach the proportioning point. The foam piping moves the concentrate from its storage source to the foam proportioner (or eductor), where the concentrate is mixed with water at the required ratio to create the foam solution that reaches the sprinklers. This piping isn't used to store water, isn't meant for drainage, and doesn't connect to the building's drainage system. Those functions belong to other parts of the system—the water supply and water piping for the main network, and drainage paths for maintenance or test operations. The critical function of foam piping is to reliably transport the concentrate to the proportioning device so the correct foam solution is produced.

SAMPLE

9. Strainers shall be installed so as to be accessible for cleaning (flushing) while maintaining system discharge during an emergency. Which option best describes this requirement?

A. Strainers must be hidden for protection

B. Strainers must be positioned near the pump

C. Strainers shall be accessible for cleaning during emergencies

D. Strainers shall be installed so as to be accessible for cleaning (flushing) while maintaining system discharge during an emergency

Strainers must be installed so they can be cleaned (flushed) without interrupting the system's discharge during an emergency. In foam-water systems, debris in a strainers can quickly choke flow and compromise discharge performance, so maintenance needs to be possible while the system remains in service. An arrangement that ensures accessibility for cleaning and provides a way to flush the strainers without stopping discharge keeps protection active during an incident. Hidden strainers or placements that don't guarantee continued flow during cleaning fail to meet the essential requirement of maintaining emergency discharge, while simply noting accessibility without addressing discharge continuity also falls short. The best description combines both accessibility and the ability to flush while the system stays pressurized and discharging in an emergency.

10. Which foam concentrate is described as very similar to protein-foam concentrate but with a synthetic fluorinated surfactant additive?

A. Fluoroprotein foam concentrate

B. Aqueous film-forming foam concentrate

C. Protein foam concentrate

D. Medium and High-expansion foam concentrate

Fluoroprotein foam concentrates combine a protein base with a synthetic fluorinated surfactant additive. This keeps the desirable characteristics of protein foams—good burnback resistance and stability—while the fluorinated additive improves spreading, wetting, and film formation on hydrocarbon fuels. That blend exactly matches the description of being very similar to protein-foam concentrate but with a synthetic fluorinated surfactant added, so it's the best choice. Pure protein foam lacks the fluorinated additive, so it wouldn't have that enhanced surface activity. AFFF concentrates are synthetic fluorinated foams without a protein base, and expansion concentrates are used for different applications (large-volume enclosure scenarios) rather than as a protein-derived foam with fluorinated additive.

SAMPLE

Next Steps

Congratulations on reaching the final section of this guide. You've taken a meaningful step toward passing your certification exam and advancing your career.

As you continue preparing, remember that consistent practice, review, and self-reflection are key to success. Make time to revisit difficult topics, simulate exam conditions, and track your progress along the way.

If you need help, have suggestions, or want to share feedback, we'd love to hear from you. Reach out to our team at hello@examzify.com.

Or visit your dedicated course page for more study tools and resources:

https://nfpa16.examzify.com

We wish you the very best on your exam journey. You've got this!

SAMPLE